

101 年 03 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
03/01	22.3	6.9	1.6	14.9	6.3
03/02	23.6	6.8	1.8	16.5	6.6
03/03	22.4	6.9	2.1	16.9	
03/04	25.0	7.0	2.0	17.1	
03/05	25.1	7.0	2.2	16.3	
03/06	26.4	7.0	2.2	17.6	7.4
03/07	25.1	7.0	1.8	19.9	7.9
03/08	24.5	7.0	1.8	20.7	8.5
03/09	23.0	7.1	2.0	21.3	
03/10	20.0	7.2	2.6	22.3	
03/11	20.2	7.1	2.5	21.5	
03/12	20.7	7.2	2.3	23.6	
03/13	22.2	7.0	2.4	21.6	8.7
03/14	22.0	7.0	2.5	19.6	8.2
03/15	22.5	7.0	2.7	18.9	7.8
03/16	24.4	7.1	2.4	17.7	
03/17	24.0	7.1	2.6	18.6	
03/18	26.5	7.1	2.7	19.4	
03/19	25.7	7.0	2.6	17.5	7.5
03/20	25.5	7.0	2.5	20.2	8.4
03/21	22.9	7.1	2.5	17.4	7.6
03/22	24.7	7.0	2.8	17.1	
03/23	26.0	7.0	2.6	17.5	
03/24	22.5	7.0	2.5	16.7	
03/25	22.9	7.0	2.8	17.5	
03/26	25.0	7.0	2.5	18.3	
03/27	24.6	6.9	2.4	18.2	7.3
03/28	25.5	7.0	2.4	19.4	8.0
03/29	25.0	7.1	2.7	19.7	8.1
03/30	26.0	7.1	2.6	19.4	
03/31	27.0	7.2	2.5	21.3	
平均值	24.0	7.0	2.4	18.9	7.7