

101 年 04 月南部科學工業園區高雄園區污水處理廠放流水質

| 日期 | Temp (°C) | pH | SS (mg/L) | COD (mg/L) | BOD ₅ (mg/L) |
|-------|-----------|-----|-----------|------------|-------------------------|
| 04/01 | 25.6 | 7.2 | 2.6 | 22.6 | |
| 04/02 | 26.5 | 7.2 | 2.7 | 23.0 | |
| 04/03 | 27.4 | 7.2 | 2.6 | 21.4 | 8.7 |
| 04/04 | 25.5 | 7.2 | 2.4 | 19.3 | |
| 04/05 | 27.9 | 7.1 | 2.8 | 20.0 | 8.4 |
| 04/06 | 26.3 | 7.0 | 2.3 | 18.5 | 7.7 |
| 04/07 | 24.8 | 7.0 | 2.4 | 18.8 | |
| 04/08 | 24.5 | 7.0 | 2.7 | 17.2 | |
| 04/09 | 27.9 | 6.9 | 2.6 | 18.4 | |
| 04/10 | 28.5 | 6.9 | 2.7 | 18.9 | 7.6 |
| 04/11 | 27.8 | 7.0 | 2.4 | 18.3 | 8.9 |
| 04/12 | 28.7 | 7.0 | 2.5 | 18.4 | 7.4 |
| 04/13 | 29.3 | 7.0 | 2.7 | 19.4 | |
| 04/14 | 28.6 | 7.0 | 2.4 | 18.2 | |
| 04/15 | 28.5 | 7.0 | 2.4 | 19.0 | |
| 04/16 | 29.1 | 7.0 | 2.8 | 17.4 | 7.1 |
| 04/17 | 28.0 | 6.9 | 2.7 | 18.8 | 7.3 |
| 04/18 | 27.7 | 6.9 | 2.3 | 17.5 | 6.4 |
| 04/19 | 27.8 | 6.9 | 2.5 | 17.6 | |
| 04/20 | 28.3 | 6.9 | 2.5 | 18.7 | |
| 04/21 | 28.2 | 7.0 | 2.6 | 18.0 | |
| 04/22 | 28.1 | 7.0 | 2.7 | 17.1 | |
| 04/23 | 28.5 | 7.0 | 2.9 | 18.8 | |
| 04/24 | 30.2 | 6.9 | 2.7 | 17.1 | 7.0 |
| 04/25 | 29.7 | 6.9 | 2.6 | 16.3 | 7.3 |
| 04/26 | 28.8 | 6.9 | 2.8 | 17.1 | 6.5 |
| 04/27 | 29.1 | 6.9 | 3.3 | 18.3 | |
| 04/28 | 27.6 | 6.9 | 2.9 | 19.1 | |
| 04/29 | 27.4 | 7.1 | 3.2 | 18.3 | |
| 04/30 | 28.8 | 7.0 | 3.3 | 18.7 | |
| 平均值 | 27.8 | 7.0 | 2.7 | 18.7 | 7.5 |