

101 年 06 月南部科學工業園區高雄園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
06/01	29.2	6.9	2.5	18.3	
06/02	27.7	6.9	2.1	16.3	
06/03	27.6	6.8	2.0	15.1	
06/04	29.2	6.8	2.2	16.3	
06/05	29.4	6.8	2.0	15.1	6.3
06/06	29.5	6.8	2.2	15.5	6.8
06/07	28.8	6.7	2.5	16.2	7.0
06/08	30.0	6.8	2.1	15.4	
06/09	24.9	6.9	2.5	14.1	
06/10	23.1	6.9	3.4	13.3	
06/11	23.0	7.1	2.5	14.1	6.3
06/12	27.6	7.0	2.8	12.4	
06/13	26.5	7.1	2.6	13.5	5.5
06/14	26.5	6.9	2.9	12.7	5.4
06/15	25.4	6.8	2.6	12.7	
06/16	26.7	7.0	2.5	13.7	
06/17	26.6	6.8	2.3	13.2	
06/18	27.3	6.8	2.5	15.5	
06/19	28.2	6.9	2.8	13.5	6.0
06/20	25.0	7.0	3.3	13.9	
06/21	26.1	7.1	2.9	15.5	6.7
06/22	26.5	7.1	2.8	15.5	6.4
06/23	28.2	7.0	2.2	16.7	
06/24	28.3	7.0	2.6	15.9	
06/25	28.2	6.9	2.2	15.1	
06/26	28.2	7.2	2.7	16.1	7.1
06/27	27.8	7.1	2.6	18.5	7.4
06/28	28.6	7.1	2.9	17.7	7.1
06/29	26.9	7.1	3.0	15.2	
06/30	26.6	7.1	2.9	16.4	
平均值	27.3	6.9	2.6	15.1	6.5