

91年3月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
03/01	26.3	7.18	3.80	36.8	12.1
03/02	25.8	6.99	3.00	50.8	--
03/03	26.2	6.98	5.50	43.6	--
03/04	26.3	6.98	6.10	47.6	15.3
03/05	25.3	6.96	6.30	23.6	--
03/06	25.1	7.00	5.20	29.8	9.7
03/07	24.5	7.10	6.40	36.7	10.1
03/08	25.3	7.04	6.30	28.4	8.2
03/09	26.7	6.96	6.30	39.5	--
03/10	26.6	6.95	6.40	34.8	--
03/11	26.7	6.95	6.60	38.7	11.2
03/12	26.2	6.94	5.40	30.8	--
03/13	26.1	6.98	6.20	29.4	8.2
03/14	26.6	7.04	6.50	37.7	14.2
03/15	27.1	6.94	5.80	37.0	15.3
03/16	26.5	7.06	6.50	44.1	--
03/17	26.1	6.98	6.30	52.2	--
03/18	26.0	6.98	6.60	46.5	16.4
03/19	26.9	6.98	6.70	52.0	--
03/20	26.7	6.90	5.80	50.4	13.2
03/21	27.3	6.97	6.60	49.6	8.2
03/22	26.8	6.94	4.80	49.6	7.4
03/23	26.3	6.95	5.20	24.4	--
03/24	25.9	6.93	3.50	28.0	--
03/25	25.9	6.92	4.80	20.2	--
03/26	26.2	6.94	6.74	20.4	--
03/27	26.7	6.95	3.00	24.4	--
03/28	26.8	6.98	6.75	46.6	--
03/29	26.3	7.00	4.25	35.3	--
03/30	26.6	7.14	2.56	46.8	--
03/31	26.9	7.13	4.06	34.5	--
平均	26.3	6.99	5.48	37.7	11.5