

91 年 4 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
04/01	26.7	6.97	4.93	29.7	--
04/02	26.1	7.00	3.50	40.3	--
04/03	26.6	7.02	3.45	45.6	--
04/04	25.6	7.14	3.50	45.6	--
04/05	26.1	7.26	4.40	36.8	--
04/06	25.9	7.33	6.00	41.6	--
04/07	25.7	7.35	3.50	36.8	--
04/08	27.6	6.96	5.30	32.0	--
04/09	27.5	7.05	6.79	33.6	--
04/10	27.1	7.17	5.22	32.7	26.5
04/11	27.0	6.97	6.50	28.7	14.0
04/12	26.4	6.87	6.20	47.6	7.0
04/13	27.1	6.88	6.30	45.3	--
04/14	27.2	6.85	4.20	39.8	--
04/15	25.7	6.78	5.12	37.5	--
04/16	27.9	6.93	5.20	43.9	--
04/17	26.9	6.94	5.30	46.8	7.8
04/18	27.1	6.94	6.10	44.5	8.2
04/19	27.7	6.94	6.20	44.5	--
04/20	28.4	6.86	5.70	44.5	--
04/21	28.7	6.94	6.20	40.6	--
04/22	28.0	6.86	4.00	48.2	15.2
04/23	27.9	7.39	2.90	43.4	11.5
04/24	28.2	6.92	3.40	44.0	11.5
04/25	28.5	6.91	2.30	35.2	10.0
04/26	27.4	6.95	4.70	18.0	10.4
04/27	26.7	7.00	6.30	45.6	--
04/28	26.3	7.61	5.00	46.4	--
04/29	27.8	6.92	5.10	44.8	--
04/30	27.7	6.90	4.50	48.0	--
平均	27.1	7.00	4.90	40.4	12.21