

91 年 6 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
06/01	28.4	6.4	7.0	39.7	--
06/02	27.2	6.2	5.1	34.9	--
06/03	28.7	6.6	2.2	23.0	--
06/04	28.3	6.7	5.5	28.3	15.4
06/05	29.2	6.7	6.4	31.9	10.2
06/06	29.2	6.8	6.7	42.2	9.8
06/07	29.1	6.8	5.6	44.4	15.2
06/08	28.1	7.2	5.0	38.2	--
06/09	27.4	7.2	6.4	46.6	--
06/10	29.6	6.5	3.0	44.3	--
06/11	29.5	6.5	3.7	34.5	15.5
06/12	29.7	6.6	3.1	31.7	16.4
06/13	29.4	6.7	2.8	29.0	14.2
06/14	29.1	6.8	4.7	33.6	11.5
06/15	30.1	7.1	4.1	42.4	--
06/16	28.4	6.9	6.0	31.2	--
06/17	28.0	6.90	6.1	51.1	--
06/18	28.7	6.80	4.5	23.0	11.7
06/19	29.8	6.90	4.20	33.2	6.8
06/20	29.7	7.80	4.3	31.8	10.2
06/21	30.4	7.00	5.4	31.0	14.3
06/22	28.9	6.90	5.3	32.5	--
06/23	27.4	7.10	3.0	8.1	--
06/24	30.4	7.00	6.0	51.2	--
06/25	30.1	7.10	6.8	38.8	--
06/26	30.0	7.10	5.0	37.6	--
06/27	30.0	7.10	5.6	29.8	--
06/28	26.8	7.20	4.7	37.4	--
06/29	27.1	7.10	--	--	--
06/30	26.4	6.90	--	--	--
平均	29.0	6.9	4.9	35.1	12.6