

92 年 12 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
12/01	25.3	7.0	4.9	30.5	13.2
12/02	25.6	6.9	6.4	38.1	21.2
12/03	27.0	7.0	3.6	41.6	16.8
12/04	26.1	7.0	5.6	50.0	15.8
12/05	26.0	7.0	5.9	56.3	20.4
12/06	26.7	6.9	2.4	44.3	--
12/07	25.6	7.0	9.3	43.5	--
12/08	26.2	7.0	6.0	33.2	19.7
12/09	26.4	6.9	4.6	44.9	22.2
12/10	25.9	7.0	3.2	37.9	20.9
12/11	26.0	7.0	4.2	39.0	21.2
12/12	25.3	6.9	3.7	49.4	21.7
12/13	24.9	7.0	3.1	58.6	--
12/14	24.9	7.0	3.9	58.6	--
12/15	24.8	7.0	4.6	47.8	20.6
12/16	24.9	6.9	3.2	42.4	20.1
12/17	24.9	7.0	3.1	38.4	20.9
12/18	24.9	7.1	3.8	33.5	20.8
12/19	24.0	7.1	3.5	33.8	20.1
12/20	26.9	7.0	4.6	43.8	--
12/21	26.8	7.0	3.2	45.4	--
12/22	24.3	6.9	4.0	48.6	21.1
12/23	24.4	7.0	5.6	42.5	20.2
12/24	24.9	7.0	4.1	31.9	17.5
12/25	25.2	7.1	3.6	38.4	21.7
12/26	25.2	7.1	4.3	25.4	18.6
12/27	25.1	7.0	3.9	33.3	--
12/28	25.2	6.9	4.2	44.4	--
12/29	24.6	7.0	4.3	24.6	--
12/30	24.3	7.1	7.7	38.2	--
12/31	23.7	7.1	4.6	36.0	--
平均	25.4	7.0	4.5	41.1	19.7