

93 年 06 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
06/01	28.8	7.0	3.3	42.2	13.4
06/02	28.2	7.1	3.2	35.9	11.9
06/03	28.3	7.1	6.1	41.2	13.8
06/04	28.5	7.4	5.6	34.4	14.2
06/05	27.4	7.0	5.1	57.6	-
06/06	28.3	7.1	3.0	54.3	-
06/07	28.8	7.2	3.9	45.2	12.3
06/08	27.5	7.1	5.8	52.6	14.2
06/09	27.5	7.1	10.3	68.1	13.2
06/10	28.1	7.1	6.1	38.5	11.6
06/11	28.5	7.2	6.8	39.6	12.9
06/12	27.3	7.0	5.9	50.8	-
06/13	27.6	7.0	5.7	44.5	-
06/14	28.3	7.1	6.4	53.1	12.4
06/15	28.1	7.1	5.7	52.7	13.6
06/16	28.6	7.1	4.4	43.9	11.9
06/17	28.0	7.1	5.9	45.5	13.6
06/18	27.7	7.2	4.0	33.6	12.4
06/19	27.6	7.0	5.4	52.1	-
06/20	27.7	7.1	6.2	56.0	-
06/21	28.1	7.1	3.7	58.3	11.3
06/22	27.7	7.0	6.7	50.0	-
06/23	28.3	7.1	3.8	39.7	13.4
06/24	28.0	7.2	5.0	48.8	13.1
06/25	28.4	7.1	4.2	51.4	11.4
06/26	27.7	7.0	4.6	62.8	-
06/27	27.9	7.0	6.0	63.6	-
06/28	28.4	7.2	5.2	41.6	13.8
06/29	28.5	7.2	4.1	40.8	11.9
06/30	28.2	7.1	5.2	43.1	12.6
平均	28.1	7.1	5.2	48.1	12.8