

93 年 07 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
07/01	28.4	7.2	3.9	40.2	13.7
07/02	28.1	7.2	8.1	21.9	13.4
07/03	27.4	7.2	3.7	42.7	-
07/04	27.2	7.1	14.7	45.2	-
07/05	27.7	7.1	5.9	46.0	12.9
07/06	28.3	7.2	4.2	33.9	14.7
07/07	28.6	7.2	5.0	44.0	12.9
07/08	28.0	7.2	4.2	37.4	14.9
07/09	28.2	7.1	5.6	41.6	12.3
07/10	28.5	7.1	3.6	62.3	-
07/11	28.4	7.1	5.9	60.7	-
07/12	28.5	7.1	7.1	61.9	12.1
07/13	28.5	7.1	9.5	50.0	14.2
07/14	28.7	7.1	8.7	40.2	11.8
07/15	28.4	7.1	7.5	42.1	13.2
07/16	28.9	7.0	8.2	39.8	12.9
07/17	27.8	7.0	8.3	46.2	-
07/18	27.8	7.0	8.9	58.2	-
07/19	28.1	7.1	8.6	44.6	10.6
07/20	28.0	7.2	5.3	47.2	12.7
07/21	28.4	7.1	7.6	40.8	10.9
07/22	28.4	7.2	6.2	43.2	14.7
07/23	28.3	7.1	8.4	47.8	11.9
07/24	27.1	7.0	5.4	40.6	-
07/25	27.1	7.0	4.4	39.0	-
07/26	28.1	7.0	8.2	43.0	12.7
07/27	27.7	7.1	7.2	41.4	11.9
07/28	27.8	7.1	9.2	60.4	14.7
07/29	28.4	7.0	4.5	38.6	12.4
07/30	27.8	7.0	7.2	39.4	12.8
07/31	28.5	7.1	7.9	63.9	-
平均	28.1	7.1	6.9	45.3	12.9