

93 年 08 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
08/01	28.5	7.0	9.0	61.4	-
08/02	27.5	7.1	9.8	44.2	11.9
08/03	27.6	7.1	4.3	47.4	12.5
08/04	28.5	7.1	6.5	47.3	12.4
08/05	27.5	7.2	6.4	63.1	15.2
08/06	28.1	7.2	7.9	57.1	14.2
08/07	27.4	7.0	7.2	57.9	-
08/08	27.4	7.0	7.5	57.1	-
08/09	28.4	7.1	10.2	59.6	13.7
08/10	28.3	7.1	9.0	42.4	12.4
08/11	28.5	7.1	5.8	39.7	10
08/12	28.2	7.1	7.5	52.6	13.6
08/13	27.2	7.2	6.1	47.0	12.4
08/14	27.0	7.0	6.1	45.1	-
08/15	27.1	7.2	13.3	61.8	-
08/16	27.1	7.2	9.9	60.1	12.1
08/17	27.8	7.0	10.8	3.6	11.8
08/18	28.3	7.1	10.9	43.4	12.4
08/19	27.3	7.0	9.5	40.1	12.0
08/20	28.8	7.2	8.8	48.3	13.9
08/21	27.0	7.1	6.4	62.3	-
08/22	27.3	7.2	16.7	61.5	-
08/23	27.5	7.1	8.8	48.6	11.2
08/24	27.5	7.0	9.5	51.2	12.6
08/25	26.6	7.0	14.8	63.4	13.8
08/26	27.4	7.1	8.6	42.9	11.2
08/27	27.5	7.1	9.9	47.0	12.3
08/28	26.8	7.0	10.9	51.4	-
08/29	27.2	7.0	12.2	56.3	-
08/30	28.6	7.2	16.4	62.8	13.5
08/31	32.0	7.3	7.9	49.6	14.1
平均	27.8	7.1	9.3	50.8	12.7