

93 年 11 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
11/01	28.6	7.2	10.7	46.1	18.6
11/02	28.3	7.1	10.6	51.2	20.4
11/03	28.1	7.1	7.7	48.3	20.1
11/04	28.3	7.2	7.5	55.1	20.8
11/05	28.3	7.2	14.7	59.0	20.6
11/06	27.6	7.2	8.3	52.2	--
11/07	27.6	7.2	10.4	47.8	--
11/08	28.5	7.1	6.6	57.5	20.6
11/09	28.3	7.3	8.6	43.1	18.5
11/10	28.2	7.1	10.0	48.4	18.2
11/11	28.1	7.1	11.5	54.4	20.1
11/12	28.0	7.2	11.9	56.8	19.5
11/13	27.3	7.1	4.7	46.5	--
11/14	27.4	7.1	6.9	40.3	--
11/15	28.5	7.2	9.0	49.6	19.5
11/16	28.0	7.1	7.0	50.2	20.6
11/17	28.3	7.1	9.9	51.6	20.4
11/18	27.3	7.1	9.0	53.2	20.7
11/19	27.3	7.1	8.7	45.1	19.3
11/20	26.5	7.1	8.6	46.6	--
11/21	26.6	7.0	10.7	52.8	--
11/22	27.5	7.1	11.1	51.2	20.1
11/23	27.5	7.2	11.3	51.6	20.6
11/24	27.3	7.2	8.7	54.9	20.2
11/25	27.2	7.0	9.0	53.2	20.4
11/26	27.5	7.0	10.6	51.6	19.7
11/27	27.4	7.1	9.3	48.4	--
11/28	27.4	7.1	8.3	39.5	--
11/29	27.3	7.0	7.3	43.5	19.5
11/30	27.4	7.0	10.3	48.8	19.8
平均	27.7	7.1	9.3	50.0	19.9