

94 年 04 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
4/01	25.9	7.6	15.0	48.2	13.6
4/02	25.9	7.4	14.4	42.1	--
4/03	25.9	7.3	15.1	56.3	--
4/04	25.3	7.1	16.6	50.8	--
4/05	26.3	7.1	14.6	47.0	--
4/06	26.7	7.7	16.2	41.6	14.6
4/07	25.9	7.0	14.8	57.6	13.6
4/08	25.4	6.6	14.5	43.4	14.0
4/09	26.4	7.2	11.1	40.2	--
4/10	25.9	7.2	9.0	40.6	--
4/11	26.7	6.5	10.6	51.2	14.6
4/12	25.8	6.9	10.4	46.1	13.6
4/13	25.1	6.7	11.8	46.8	14.0
4/14	24.3	6.8	11.5	48.2	14.6
4/15	25.8	6.8	12.3	44.0	13.6
4/16	25.4	6.8	14.7	42.4	--
4/17	25.4	6.8	13.2	47.2	--
4/18	26.7	6.8	13.0	45.6	13.1
4/19	26.5	6.8	14.4	43.6	12.7
4/20	27.1	6.9	15.3	45.2	12.9
4/21	26.7	6.6	14.7	53.2	12.5
4/22	25.5	6.9	14.8	55.6	13.0
4/23	26.0	6.8	16.0	49.2	--
4/24	26.2	6.9	15.5	50.8	--
4/25	25.6	6.9	14.8	56.3	13.2
4/26	26.2	6.8	14.5	58.3	12.9
4/27	27.0	6.8	13.8	45.3	13.3
4/28	26.5	6.5	14.4	52.8	13.5
4/29	27.7	6.6	10.5	44.4	12.7
4/30	27.1	6.7	13.8	58.6	--
平均	26.1	6.9	13.7	48.4	13.3