

94 年 07 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
7/01	28.7	7.1	10.8	52.4	14.2
7/02	27.9	7.1	11.7	56.8	--
7/03	28.3	7.0	14.0	52.8	--
7/04	28.7	7.0	12.1	60.0	14.0
7/05	27.6	7.0	15.8	65.1	14.5
7/06	27.6	7.0	16.4	45.9	13.7
7/07	27.6	7.1	12.2	44.5	12.7
7/08	27.4	6.8	13.5	52.8	13.0
7/09	28.0	7.2	11.0	51.8	--
7/10	28.4	7.0	13.8	43.7	--
7/11	28.4	7.0	11.0	49.0	13.5
7/12	28.7	6.9	12.0	41.9	13.0
7/13	28.7	7.1	10.0	53.0	13.7
7/14	28.8	7.0	8.2	57.0	13.9
7/15	28.8	6.9	10.4	49.0	13.2
7/16	28.0	7.1	12.4	41.8	--
7/17	27.4	7.0	13.2	55.4	--
7/18	颱風假				--
7/19	26.9	7.1	12.2	39.0	12.7
7/20	25.8	7.0	12.5	38.5	12.5
7/21	26.5	7.0	13.2	53.1	13.9
7/22	27.2	7.1	11.8	35.7	12.5
7/23	27.0	7.1	12.5	53.1	--
7/24	26.9	7.1	11.2	46.8	--
7/25	27.4	7.0	11.8	43.3	12.8
7/26	27.6	7.0	12.5	38.2	12.4
7/27	29.2	6.8	13.3	50.8	13.0
7/28	28.6	6.9	16.2	44.5	12.8
7/29	28.5	6.8	13.2	51.5	13.6
7/30	28.3	7.1	13.8	51.1	--
7/31	27.9	7.1	12.6	62.5	--
平均	27.9	7.0	12.5	49.4	13.3