

94 年 09 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
9/01	颱風假				
9/02	28.6	6.9	8.6	49.2	14.1
9/03	28.5	6.7	12.6	50.6	
9/04	28.5	6.8	13.0	57.7	
9/05	28.8	7.0	11.0	57.7	15.0
9/06	29.4	6.9	9.8	46.8	13.9
9/07	28.7	6.9	5.3	45.9	14.0
9/08	29.0	7.0	11.6	47.2	15.3
9/09	28.7	7.0	9.1	41.5	13.7
9/10	29.0	7.0	9.0	48.4	
9/11	29.3	7.0	10.1	43.5	
9/12	28.8	6.9	12.0	36.3	13.2
9/13	28.7	7.1	10.6	38.9	13.7
9/14	28.7	7.0	6.6	40.2	13.4
9/15	28.8	7.0	10.6	42.9	13.9
9/16	28.8	6.9	11.0	44.1	14.2
9/17	27.0	6.9	11.0	60.1	
9/18	26.8	7.0	12.2	50.8	
9/19	30.0	6.9	12.0	45.7	14.4
9/20	30.2	6.9	12.6	42.6	13.5
9/21	30.0	6.9	15.2	45.1	14.2
9/22	30.1	7.0	15.2	38.3	13.4
9/23	30.2	6.9	15.5	42.6	13.6
9/24	30.0	6.9	13.9	53.9	
9/25	28.1	6.8	16.4	49.2	
9/26	30.8	7.0	11.2	39.4	14.2
9/27	30.2	6.9	12.0	49.2	12.1
9/28	30.2	6.8	10.4	46.4	12.4
9/29	30.1	6.9	13.6	39.7	12.2
9/30	29.9	7.0	11.2	51.2	13.0
平均	29.2	6.9	11.5	46.4	13.7