

95 年 05 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
5/01	26.5	6.8	11.0	45.4	11.2
5/02	26.5	6.9	8.3	51.6	18.9
5/03	26.3	6.8	16.6	43.8	17.6
5/04	25.7	6.9	11.0	47.8	18.1
5/05	26.3	6.8	4.8	41.5	16.2
5/06	27.4	6.9	3.7	48.6	--
5/07	27.3	7.0	3.9	54.2	--
5/08	27.3	6.8	4.0	51.8	10.4
5/09	27.4	6.9	4.7	42.9	16.0
5/10	27.5	6.9	5.1	54.3	15.7
5/11	27.6	6.9	5.0	30.7	19.1
5/12	26.5	6.9	6.2	46.2	17.1
5/13	27.9	7.0	3.2	38.1	--
5/14	28.0	6.8	7.7	33.3	--
5/15	26.5	6.7	5.4	36.5	18.3
5/16	26.6	6.9	7.9	42.1	16.2
5/17	26.5	6.8	10.6	43.1	19.5
5/18	颱風假	--	--	--	--
5/19	26.5	6.8	9.5	39.8	16.2
5/20	26.5	6.8	4.8	46.0	--
5/21	26.7	6.8	5.1	37.3	--
5/22	27.5	6.8	8.0	42.1	18.0
5/23	26.5	6.9	5.8	37.9	19.1
5/24	27.4	6.9	4.3	46.4	16.2
5/25	27.4	6.7	5.5	34.4	14.1
5/26	27.6	6.7	7.8	38.2	—
5/27	26.5	6.7	4.5	41.0	--
5/28	25.8	6.9	4.1	38.6	--
5/29	26.5	6.7	10.4	39.8	—
5/30	26.3	6.7	12.1	44.8	15.4
5/31	27.1	6.9	9.4	39.4	--
平均	26.9	6.8	7.0	42.6	16.5