

96 年 03 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
03/01	25.4	7.0	5.9	35.0	11.7
03/02	25.4	7.0	6.0	46.6	13.9
03/03	24.6	7.0	5.2	41.4	--
03/04	24.9	6.9	5.5	39.0	--
03/05	25.4	7.0	5.6	43.0	14.2
03/06	23.7	6.9	5.9	38.9	10.5
03/07	23.6	6.8	6.5	36.8	13.7
03/08	24.3	6.8	6.8	36.3	12.2
03/09	24.7	6.9	7.0	36.2	12.6
03/10	26.0	6.9	4.9	33.2	--
03/11	25.9	6.9	5.2	35.6	--
03/12	25.2	6.8	5.8	41.3	12.7
03/13	25.4	6.8	5.2	37.1	11.0
03/14	25.8	6.8	7.3	37.2	12.9
03/15	25.6	6.9	13.5	44.4	11.8
03/16	25.7	6.9	11.9	44.0	12.0
03/17	25.5	7.0	10.3	42.8	--
03/18	24.5	6.9	6.2	36.8	--
03/19	24.5	6.9	6.2	35.6	11.5
03/20	24.5	6.9	4.1	37.0	10.1
03/21	24.6	6.9	5.8	38.1	11.4
03/22	25.4	6.8	9.3	38.3	10.9
03/23	24.7	6.9	7.2	39.2	10.9
03/24	24.4	7.0	9.7	34.4	--
03/25	24.7	7.0	9.7	35.1	--
03/26	26.3	6.8	7.8	42.2	12.4
03/27	26.0	6.8	6.8	37.2	11.3
03/28	25.4	6.9	5.2	50.4	12.9
03/29	25.4	7.0	5.8	39.8	10.3
03/30	25.5	7.0	5.3	38.9	11.4
03/31	25.0	6.9	4.0	32.1	--
平均	25.1	6.9	6.8	38.8	11.9