

96 年 06 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
06/01	27.7	7.0	7.3	38.3	11.3
06/02	27.4	7.0	7.3	38.1	--
06/03	27.1	6.9	6.6	38.8	--
06/04	27.0	6.9	7.3	40.0	12.1
06/05	27.4	6.9	8.3	37.2	14.5
06/06	26.8	6.9	8.9	49.0	13.0
06/07	27.0	6.9	10.2	39.1	12.8
06/08	26.5	7.0	8.8	38.4	10.9
06/09	25.9	7.0	8.7	37.4	--
06/10	26.3	6.9	7.3	41.4	--
06/11	26.6	6.9	7.9	51.4	11.9
06/12	26.2	7.0	9.5	52.4	12.0
06/13	26.5	6.8	7.9	39.8	11.1
06/14	27.5	7.0	8.5	42.2	13.1
06/15	27.8	7.0	11.0	46.8	11.8
06/16	27.7	6.9	8.5	50.4	--
06/17	27.8	6.9	8.3	45.9	--
06/18	27.7	6.9	6.1	44.7	--
06/19	27.6	6.9	6.9	40.6	--
06/20	27.8	6.8	5.2	41.5	12.3
06/21	28.6	7.0	9.7	39.0	11.4
06/22	28.6	7.0	9.2	39.7	11.9
06/23	28.6	6.9	8.5	40.9	12.1
06/24	27.7	7.0	4.7	45.4	--
06/25	26.4	7.0	8.8	49.0	13.0
06/26	27.5	7.1	11.5	50.6	13.8
06/27	29.2	7.1	11.9	55.1	13.6
06/28	28.6	7.0	6.6	42.8	12.8
06/29	27.6	7.0	8.1	53.4	13.0
06/30	27.6	6.9	5.1	44.4	--
平均	27.4	7.0	8.2	43.8	12.4