

## 98 年 11 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
11/01	26.6	6.8	4.0	31.0	--
11//02	26.2	6.7	4.4	34.1	6.5
11/03	25.9	6.7	4.8	34.1	5.4
11/04	25.9	6.6	4.9	34.4	4.9
11/05	26.0	6.7	3.4	32.9	4.7
11//06	26.6	6.7	4.3	27.1	6.1
11/07	26.7	6.7	2.9	34.3	--
11/08	26.6	6.7	3.8	26.3	--
11/09	26.9	6.8	3.7	34.7	4.5
11/10	27.1	6.7	4.6	32.1	5.1
11/11	27.0	6.7	3.4	29.8	6.1
11/12	26.9	6.7	3.5	30.9	5.8
11/13	26.8	6.7	4.0	30.4	6.5
11/14	26.7	6.7	3.4	35.1	--
11/15	26.8	6.7	4.1	32.7	--
11/16	25.8	6.7	3.9	31.5	5.3
11/17	25.8	6.8	5.4	34.1	5.1
11/18	25.6	6.7	6.0	30.0	4.5
11/19	25.5	6.8	4.8	30.0	5.9
11/20	25.8	6.8	3.4	32.0	6.0
11/21	25.6	6.9	4.6	29.1	--
11/22	25.3	6.8	3.6	29.9	--
11/23	25.1	6.7	3.6	30.3	5.2
11/24	26.1	6.8	3.6	29.9	6.0
11/25	26.2	6.8	3.3	29.0	4.6
11/26	26.3	6.9	4.1	29.4	5.8
11/27	26.1	6.9	3.7	30.4	5.8
11/28	25.5	7.0	3.8	27.2	--
11/29	25.9	6.8	5.2	36.8	--
11/30	25.4	6.8	6.0	29.2	6.4
平均	26.2	6.8	4.1	31.3	5.5