

## 99 年 05 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
05/01	26.2	6.9	8.2	37.6	--
05//02	25.9	6.9	7.6	38.4	--
05/03	26.5	6.8	7.4	28.8	6.0
05/04	26.9	6.9	7.1	35.1	7.0
05/05	27.1	7.0	5.2	31.9	6.4
05//06	27.3	6.8	9.4	32.5	7.5
05/07	27.3	6.9	6.3	35.7	7.1
05/08	27.2	7.0	9.5	31.6	--
05/09	27.0	6.9	4.5	34.0	--
05/10	27.8	6.7	4.8	32.0	6.6
05/11	27.4	6.9	4.8	36.7	7.3
05/12	27.6	6.8	7.1	40.2	6.3
05/13	28.0	6.9	5.2	36.1	7.3
05/14	27.9	7.0	4.4	32.9	8.1
05/15	26.3	6.9	2.9	37.8	--
05/16	26.3	7.1	3.3	36.9	--
05/17	27.6	6.8	4.6	32.5	6.2
05/18	28.0	6.7	5.9	35.2	7.1
05/19	27.9	6.8	5.4	32.3	7.7
05/20	28.1	6.8	4.3	36.9	8.2
05/21	28.2	6.8	3.6	37.3	7.8
05/22	27.6	6.9	2.6	32.4	--
05/23	27.1	7.0	3.0	35.6	--
05/24	27.2	6.8	4.5	30.0	6.3
05/25	27.3	7.0	3.9	36.3	7.4
05/26	28.0	6.9	4.2	30.6	6.8
05/27	28.2	6.8	3.9	36.8	7.6
05/28	28.0	6.8	4.4	30.0	7.2
05/29	26.2	7.0	4.7	36.5	--
05/30	26.6	6.9	3.2	37.3	--
05/31	27.5	6.9	4.0	34.5	7.5
平均	27.3	6.9	5.2	34.6	7.1