

99 年 08 月台南科學工業園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
08/01	27.2	6.8	5.3	34.8	--
08//02	28.2	6.6	4.9	35.2	7.4
08/03	28.0	6.8	6.5	35.5	8.2
08/04	28.3	6.7	5.4	31.3	6.3
08/05	28.1	6.7	5.9	34.9	8.6
08//06	28.3	6.8	4.0	30.8	6.2
08/07	25.5	6.8	4.6	36.8	--
08/08	26.3	6.8	6.0	35.2	--
08/09	28.3	6.8	5.4	35.2	7.9
08/10	28.4	6.8	5.9	31.1	8.5
08/11	28.5	7.0	7.1	36.7	7.3
08/12	28.1	7.0	4.7	29.4	8.9
08/13	28.2	6.9	7.6	35.3	7.5
08/14	27.6	7.0	3.1	28.0	--
08/15	26.4	6.8	4.9	34.4	--
08/16	27.9	6.8	4.9	35.2	8.3
08/17	27.8	6.8	5.4	34.8	7.8
08/18	28.1	6.8	5.8	36.7	7.4
08/19	28.2	6.8	6.0	32.7	8.3
08/20	28.2	7.0	5.3	35.7	7.6
08/21	26.9	6.9	3.2	36.8	--
08/22	26.9	7.0	4.6	29.2	--
08/23	27.8	6.9	5.5	37.2	11.4
08/24	27.8	6.9	5.9	34.4	7.3
08/25	28.1	6.8	5.0	29.5	8.9
08/26	27.7	7.0	4.8	34.3	7.0
08/27	28.2	6.9	5.1	36.7	6.2
08/28	26.9	6.9	5.6	35.2	--
08/29	27.1	6.8	4.3	32.8	--
08/30	27.2	6.9	7.6	36.4	7.1
08/31	27.8	6.8	5.1	38.4	8.3
平均	27.7	6.8	5.3	34.2	7.8