

101 年 03 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
03/01	25.5	7.0	5.8	32.3	9.6
03/02	26.1	7.0	4.9	27.0	13.0
03/03	26.5	7.0	6.2	28.9	--
03/04	25.5	7.0	7.5	28.9	--
03/05	26.5	7.0	7.6	28.1	10.1
03/06	27.2	7.0	8.0	36.1	11.2
03/07	27.0	6.9	6.5	31.6	8.5
03/08	26.6	6.9	5.2	35.1	9.3
03/09	26.1	7.0	5.1	23.2	7.4
03/10	25.5	7.0	4.0	28.5	--
03/11	26.7	7.1	5.2	35.7	--
03/12	25.2	7.0	5.4	24.5	7.9
03/13	24.8	7.0	9.0	33.2	8.9
03/14	25.7	7.1	5.1	27.6	10.0
03/15	25.9	7.0	5.1	27.9	9.2
03/16	26.4	6.9	5.5	28.7	6.5
03/17	27.2	6.9	5.4	28.2	--
03/18	27.2	7.0	5.5	28.2	--
03/19	27.4	6.9	4.8	24.6	7.7
03/20	26.6	6.8	6.2	35.2	6.4
03/21	26.8	6.9	5.1	27.6	9.0
03/22	27.1	6.8	5.3	26.5	9.5
03/23	27.6	6.8	4.5	33.9	11.5
03/24	24.4	6.9	4.8	36.4	--
03/25	25.4	7.0	5.9	31.6	--
03/26	26.0	6.9	6.7	35.2	10.2
03/27	27.0	6.9	7.8	25.2	8.1
03/28	27.0	7.0	7.3	23.6	9.2
03//29	26.9	7.0	6.2	31.2	8.4
03/30	27.4	7.0	4.1	39.2	10.6
03/31	27.2	7.0	5.3	28.9	--
平均值	26.4	7.0	5.8	30.1	9.2