

101 年 06 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
06/01	28.8	7.0	3.6	27.5	12.1
06/02	28.7	7.0	5.8	29.4	--
06/03	28.7	7.0	10.4	32.9	--
06/04	28.2	6.9	7.7	34.5	13.0
06/05	27.8	6.9	5.3	34.9	10.0
06/06	27.8	7.0	5.7	32.9	11.7
06/07	28.4	6.9	4.4	30.6	9.0
06/08	28.6	6.9	4.2	25.4	9.5
06/09	27.2	6.9	11.3	35.5	--
06/10	26.9	6.9	13.6	27.5	--
06/11	27.5	6.9	4.0	29.1	8.0
06/12 註 1	--	--	--	--	--
06/13	27.2	7.0	5.3	31.1	9.2
06/14	27.3	7.0	6.6	41.4	10.4
06/15	27.1	6.9	8.8	30.6	12.6
06/16	26.0	6.9	6.8	25.8	--
06/17	26.5	7.0	6.4	34.1	--
06/18	27.5	6.9	6.3	31.0	10.0
06/19	27.5	7.0	5.7	31.3	11.7
06/20	27.0	7.0	7.7	26.9	13.1
06/21	26.8	7.0	6.2	24.0	7.3
06/22	27.3	6.9	6.7	26.0	8.2
06/23	28.0	7.0	7.1	32.5	--
06/24	28.5	7.0	7.4	23.0	--
06/25	27.7	7.0	5.7	23.0	8.5
06/26	28.0	7.0	8.3	41.3	7.1
06/27	28.2	6.9	5.3	30.2	8.8
06/28	28.9	6.9	6.3	31.5	9.3
06/29	29.5	6.9	6.7	29.9	10.3
06/30	28.5	7.0	5.2	40.2	--
平均值	27.8	7.0	6.7	30.8	10.0

備註 1：颱風停班停課