

101 年 10 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
10/01	27.4	7.0	7.0	25.8	7.7
10/02	27.3	7.1	6.9	29.4	8.8
10/03	28.4	7.2	7.2	24.8	8.6
10/04	27.4	6.9	6.8	26.3	9.2
10/05	27.5	7.1	5.6	27.6	9.7
10/06	29.3	7.0	8.6	31.6	--
10/07	29.9	7.0	11.1	31.6	--
10/08	27.0	7.0	5.2	27.6	8.3
10/09	27.2	7.0	6.0	33.1	9.9
10/10	26.2	7.0	4.6	33.3	--
10/11	26.9	7.0	7.8	29.4	10.3
10/12	27.5	7.0	5.3	25.9	9.5
10/13	26.6	6.9	4.9	28.4	--
10/14	26.2	6.9	6.0	26.4	--
10/15	29.7	6.9	6.8	30.0	9.5
10/16	27.6	7.0	9.3	25.4	10.2
10/17	27.5	7.0	5.2	31.2	10.9
10/18	27.6	6.8	3.9	22.8	9.8
10/19	26.5	7.0	3.8	26.4	9.3
10/20	27.2	6.9	4.2	23.8	--
10/21	27.3	6.9	5.5	32.9	--
10/22	24.2	6.9	5.7	26.6	8.0
10/23	28.2	7.0	6.9	28.2	10.1
10/24	27.6	7.0	5.0	33.3	10.5
10/25	27.4	6.9	6.4	33.2	9.9
10/26	27.6	6.9	4.9	26.4	9.2
10/27	27.7	6.9	6.6	23.8	--
10/28	28.3	6.9	11.4	31.7	--
10/29	28.0	6.8	5.8	23.4	10.2
10/30	26.9	7.0	5.5	23.8	9.7
10/31	27.5	7.0	4.1	25.8	10.7
平均值	27.5	7.0	6.3	28.1	9.5