

102 年 06 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
06/01	28.6	6.8	7.7	23.2	--
06/02	28.9	7.0	8.2	25.6	--
06/03	28.8	7.0	7.7	23.4	8.3
06/04	28.5	6.6	4.9	23.1	6.7
06/05	28.5	6.8	6.3	29.3	--
06/06	28.4	6.6	7.3	25.7	7.6
06/07	28.7	7.1	9.7	23.5	7.2
06/08	27.9	6.6	8.0	24.2	--
06/09	28.3	6.6	7.0	27.6	--
06/10	28.4	6.9	7.8	25.6	8.8
06/11	28.3	6.9	9.3	28.4	8.2
06/12	28.4	7.0	8.7	26.9	--
06/13	28.3	7.2	8.3	28.1	7.8
06/14	28.2	7.2	7.9	29.8	9.1
06/15	28.0	7.1	9.0	27.4	--
06/16	28.4	7.1	7.8	24.0	--
06/17	27.6	7.0	6.7	30.8	9.3
06/18	28.4	7.0	6.2	33.9	9.0
06/19	28.4	7.0	8.6	28.0	--
06/20	28.4	7.0	8.2	26.4	9.8
06/21	28.7	7.2	7.1	32.3	9.3
06/22	28.4	7.0	7.7	28.1	--
06/23	27.6	7.0	9.1	27.7	--
06/24	27.9	7.1	9.1	26.3	9.2
06/25	27.6	6.6	7.3	26.6	9.9
06/26	28.0	6.9	9.9	33.7	--
06/27	28.5	7.0	8.1	28.2	10.0
06/28	29.0	6.9	6.5	26.4	8.7
06/29	27.5	6.9	8.5	27.8	--
06/30	27.8	6.9	7.3	26.6	--
平均值	28.3	6.9	7.9	27.3	8.7