

103 年 01 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
01/01	24.0	6.9	4.9	27.2	--
01/02	23.8	6.9	5.4	29.2	7.3
01/03	25.3	6.9	5.7	26.7	6.8
01/04	25.4	7.0	7.1	24.6	--
01/05	24.7	6.9	5.0	25.4	--
01/06	23.6	6.8	5.6	28.6	--
01/07	24.7	6.9	6.4	32.7	8.2
01/08	24.9	6.8	6.4	24.3	7.8
01/09	23.6	6.9	5.6	30.4	6.4
01/10	24.3	7.0	5.8	22.0	6.9
01/11	25.2	7.0	5.3	30.5	--
01/12	24.7	7.0	6.3	25.7	--
01/13	24.0	6.8	5.6	29.3	--
01/14	24.1	6.9	9.1	28.1	6.6
01/15	23.7	6.9	6.2	26.5	7.5
01/16	23.6	6.9	6.7	22.3	7.4
01/17	24.0	7.0	5.5	31.0	8.2
01/18	23.3	6.9	3.6	22.9	--
01/19	23.4	6.9	6.4	24.5	--
01/20	23.6	6.9	8.7	28.5	--
01/21	22.7	6.8	7.1	26.3	7.6
01/22	23.2	6.9	5.9	25.8	8.7
01/23	22.7	7.0	5.5	27.3	8.2
01/24	22.8	7.0	7.2	27.2	7.8
01/25	24.9	7.0	5.4	26.4	--
01/26	24.9	6.9	8.4	31.2	--
01/27	22.7	6.8	8.5	29.6	--
01/28	24.1	6.9	7.8	29.0	8.1
01/29	21.7	6.9	8.4	27.5	7.2
01/30	25.4	6.9	9.2	25.9	--
01/31	26.3	6.9	9.7	27.5	--
平均值	24.0	6.9	6.6	27.2	7.5