

103 年 02 月南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	PH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
02/01	26.4	7.0	8.4	25.9	--
02/02	25.3	7.0	6.8	28.3	--
02/03	25.7	7.0	10.4	31.0	--
02/04	24.9	7.0	5.8	26.2	--
02/05	25.2	7.1	5.7	26.6	7.5
02/06	24.5	7.2	6.4	26.2	8.4
02/07	25.8	6.9	8.2	25.0	8.8
02/08	25.4	7.2	6.7	28.6	--
02/09	24.8	7.2	8.8	27.0	--
02/10	22.7	7.0	10.6	25.4	--
02/11	23.2	7.1	8.1	27.7	9.3
02/12	20.2	6.8	6.3	28.1	8.7
02/13	22.0	7.0	6.8	31.2	7.5
02/14	24.0	6.9	7.0	27.2	8.6
02/15	22.4	6.9	9.0	26.8	--
02/16	23.4	6.9	9.0	26.0	--
02/17	24.9	6.9	7.4	25.2	--
02/18	24.8	6.9	8.1	27.2	7.4
02/19	24.2	7.0	7.0	26.3	7.4
02/20	23.5	7.0	10.4	28.3	8.5
02/21	24.4	6.8	8.6	23.1	7.8
02/22	24.2	6.9	8.9	28.4	--
02/23	24.2	6.9	8.3	26.8	--
02/24	24.5	6.8	9.8	27.6	--
02/25	24.4	6.9	7.5	29.9	8.5
02/26	24.4	7.0	6.9	30.3	8.4
02/27	24.4	7.0	7.1	25.9	8.6
02/28	25.0	6.9	7.8	25.2	
平均值	24.2	7.0	7.9	27.2	8.2