

103 年 10 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
10/01	29.0	6.9	10.3	27.3	6.7
10/02	28.9	6.9	6.5	28.9	7.3
10/03	28.7	7.0	6.9	30.6	8.0
10/04	29.4	7.0	6.8	29.4	--
10/05	29.9	6.9	7.4	27.8	--
10/06	27.6	6.9	6.7	29.0	--
10/07	27.6	7.0	9.6	27.7	7.5
10/08	28.0	6.7	9.1	26.6	6.8
10/09	28.1	6.9	7.8	28.4	7.0
10/10	26.6	6.8	8.9	28.6	--
10/11	26.8	6.7	7.2	27.8	--
10/12	28.3	6.8	9.2	28.6	--
10/13	28.0	6.8	7.7	27.0	--
10/14	27.7	6.9	8.2	32.4	7.2
10/15	27.7	7.0	6.8	26.0	6.8
10/16	27.5	6.9	7.2	26.6	7.4
10/17	27.4	6.9	6.0	28.3	7.1
10/18	28.3	6.9	6.5	32.8	--
10/19	27.8	6.9	7.9	27.9	--
10/20	27.9	7.0	6.5	31.2	--
10/21	27.8	7.0	5.5	34.4	6.9
10/22	28.4	6.9	9.1	24.4	8.0
10/23	28.0	6.9	7.5	31.3	7.7
10/24	27.8	6.9	7.2	34.7	8.2
10/25	28.6	6.8	7.2	36.2	--
10/26	28.0	6.9	8.2	29.7	--
10/27	27.9	6.8	7.6	29.7	--
10/28	28.0	7.0	7.4	31.6	6.8
10/29	27.7	6.8	8.8	29.3	7.2
10/30	28.0	6.9	6.4	27.0	7.9
10/31	27.8	7.0	7.4	29.8	6.7
平均值	28.0	6.9	7.6	29.4	7.3