

105 年 1 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
01/01	25.1	7.0	15.0	29.3	3.3
01/02	24.3	7.0	15.0	33.3	<2.0
01/03	23.9	7.0	14.8	47.8	<2.0
01/04	25.9	7.0	10.3	47.0	
01/05	25.9	6.9	12.3	39.4	
01/06	26.6	6.9	12.5	32.1	
01/07	25.8	6.9	12.3	30.3	<2.0
01/08	25.6	7.0	14.0	31.9	<2.0
01/09	25.2	6.9	11.5	28.3	2.5
01/10	25.9	7.1	13.4	33.1	<2.0
01/11	25.4	6.9	18.0	37.1	
01/12	25.2	7.0	14.8	32.0	
01/13	25.4	6.9	12.0	33.1	
01/14	24.9	7.0	11.3	29.2	2.1
01/15	24.8	6.8	13.0	26.0	2.2
01/16	25.2	6.9	16.6	33.2	2.4
01/17	25.1	6.9	16.2	32.4	<2.0
01/18	25.0	6.8	9.6	34.0	
01/19	24.4	6.9	17.2	30.4	
01/20	24.9	7.0	11.8	30.1	
01/21	25.6	6.9	15.6	30.7	<2.0
01/22	25.3	6.8	10.2	27.9	5.8
01/23	23.8	6.8	11.6	30.6	<2.0
01/24	21.5	6.9	8.4	31.7	6.4
01/25	22.6	7.1	7.2	26.2	
01/26	23.4	7.1	10.6	29.5	
01/27	24.4	7.1	11.1	31.2	2.8
01/28	24.5	7.2	14.8	29.9	3.3
01/29	24.8	7.3	12.4	28.7	<2.0
01/30	24.8	7.1	11.6	33.9	<2.0
01/31	24.8	7.0	12.9	27.4	
平均值	24.8	7.0	12.8	32.2	