

## 105 年 2 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
02/01	24.5	7.2	9.0	37.7	5.7
02/02	23.5	7.2	10.2	38.4	5.4
02/03	24.5	7.0	10.5	33.9	
02/04	24.4	7.0	9.2	28.7	5.9
02/05	24.0	7.2	10.0	32.8	5.4
02/06	22.5	7.3	14.8	31.9	
02/07	21.0	7.2	12.5	31.9	
02/08	22.7	7.1	9.4	20.7	
02/09	23.1	7.4	7.2	22.3	
02/10	23.6	7.1	10.5	23.6	
02/11	24.7	7.0	8.3	34.8	
02/12	24.5	7.1	5.9	23.6	
02/13	24.2	7.2	4.6	21.0	
02/14	25.5	7.2	5.5	22.6	
02/15	24.9	7.0	6.0	22.6	
02/16	22.4	7.2	8.5	31.7	2.1
02/17	24.6	7.2	8.5	35.7	4.4
02/18	23.8	6.9	11.0	30.2	<2.0
02/19	25.2	6.7	10.0	31.0	<2.0
02/20	24.0	6.7	9.0	23.5	
02/21	24.4	6.7	12.8	34.3	
02/22	24.8	6.8	10.5	27.5	
02/23	25.0	6.8	9.2	36.0	3.6
02/24	24.4	6.8	9.6	31.2	2.5
02/25	24.5	6.8	9.8	32.7	2.2
02/26	24.7	6.8	7.9	26.0	3.1
02/27	24.9	6.8	7.1	24.3	
02/28	25.3	6.8	5.4	25.9	
02/29	25.7	6.7	11.2	33.1	
平均值	24.2	7.0	9.1	29.3	3.7