

105 年 3 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
03/01	23.7	6.6	10.5	28.3	<2.0
03/02	25.2	7.0	11.4	31.2	11.3
03/03	23.8	7.0	7.9	31.1	5.9
03/04	25.2	7.0	7.9	32.3	2.5
03/05	26.1	6.9	6.8	31.7	
03/06	26.2	7.0	5.1	34.5	
03/07	26.2	7.1	8.2	33.7	
03/08	26.7	7.1	8.6	31.7	<2.0
03/09	26.8	7.0	11.1	23.4	3.9
03/10	24.2	7.1	4.6	24.3	2.2
03/11	24.3	7.3	5.2	27.6	2.3
03/12	24.7	7.2	5.6	31.9	
03/13	25.3	7.0	7.8	31.9	
03/14	24.8	7.2	5.6	27.1	
03/15	24.8	7.0	6.8	27.9	2.5
03/16	25.3	6.9	8.4	28.6	2.4
03/17	25.8	7.0	15.0	35.7	2.6
03/18	26.1	6.9	15.2	34.7	2.2
03/19	25.5	7.0	14.9	31.1	
03/20	25.9	6.9	10.0	31.1	
03/21	25.9	7.0	12.4	30.7	
03/22	25.8	6.9	5.7	31.6	<2.0
03/23	26.1	7.0	6.2	32.4	6.5
03/24	24.8	7.0	8.3	35.2	5.4
03/25	25.2	6.9	8.8	31.5	<2.0
03/26	24.0	6.7	11.8	29.2	
03/27	24.0	6.8	9.2	30.8	
03/28	25.0	6.9	10.4	34.0	<2.0
03/29	24.3	7.1	9.9	28.4	2.1
03/30	25.6	7.0	6.0	25.7	
03/31	26.0	7.0	7.6	33.6	<2.0
平均值	25.3	7.0	8.8	30.7	3.4