

107 年 04 月科技部南部科學工業園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
4/01	26.6	6.6	6.1	25.2	
4/02	27.6	6.6	7.5	25.6	<2.0
4/03	28.0	6.7	5.7	26.2	<2.0
4/04	28.5	6.5	6.3	24.9	
4/05	28.2	6.9	6.0	23.7	
4/06	27.6	6.9	6.5	24.1	
4/07	26.6	6.8	6.2	24.5	
4/08	25.8	6.8	9.6	25.7	
4/09	26.5	6.6	6.3	21.2	
4/10	26.8	6.9	6.9	26.4	3.9
4/11	27.4	6.7	8.6	29.5	6.7
4/12	28.0	6.6	5.3	25.6	<2.0
4/13	28.3	6.7	5.4	27.3	<2.0
4/14	29.1	6.8	4.8	25.9	
4/15	29.7	6.7	3.7	27.1	
4/16	27.8	7.0	3.9	32.4	
4/17	27.2	6.9	4.7	29.6	5.4
4/18	26.7	6.8	5.6	30.8	<2.0
4/19	27.6	6.8	4.8	26.6	<2.0
4/20	27.7	6.7	4.7	30.2	<2.0
4/21	28.0	6.9	4.4	29.4	
4/22	25.6	6.6	5.7	27.0	
4/23	28.4	6.5	5.2	26.6	
4/24	28.4	6.9	4.4	26.8	<2.0
4/25	28.2	6.9	4.2	25.6	<2.0
4/26	27.9	6.9	3.8	25.7	4.5
4/27	28.2	7.1	2.8	28.8	<2.0
4/28	29.8	6.5	4.9	25.7	
4/29	28.7	6.8	5.8	27.8	
4/30	28.6	6.8	7.4	22.0	
平均值	27.8	6.8	5.6	26.6	2.9