

## 108 年 03 月南部科學園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD <sub>5</sub> (mg/L)
03/01	28.3	6.5	8.2	29.7	
03/02	24.5	6.7	3.5	30.1	
03/03	27.9	6.6	6.7	26.1	
03/04	26.2	6.5	6.4	27.3	
03/05	26.2	6.6	3.1	19.7	<2.0
03/06	26.6	6.6	5.9	27.2	<2.0
03/07	25.8	6.6	4.2	28.3	<2.0
03/08	24.8	6.6	2.5	25.5	<2.0
03/09	25.4	6.5	4.8	30.8	
03/10	27.2	6.5	3.7	27.6	
03/11	25.9	6.6	5.9	26.8	
03/12	25.9	6.6	4.1	21.8	9.3
03/13	26.0	6.5	4.6	24.7	<2.0
03/14	26.2	6.7	8.3	23.3	<2.0
03/15	25.8	6.7	4.1	23.1	<2.0
03/16	27.4	6.6	7.4	19.5	
03/17	28.1	6.5	7.5	24.6	
03/18	26.4	6.8	5.5	19.3	
03/19	26.5	6.7	6.3	24.7	<2.0
03/20	27.0	6.6	5.9	31.0	<2.0
03/21	27.0	6.5	4.3	23.5	<2.0
03/22	27.3	6.7	5.0	22.0	<2.0
03/23	23.5	6.7	8.8	20.5	
03/24	27.8	6.5	6.7	21.3	
03/25	26.3	6.5	6.8	21.3	
03/26	26.3	6.7	4.8	22.3	<2.0
03/27	26.5	6.7	4.7	25.2	<2.0
03/28	26.9	6.6	5.2	22.3	<2.0
03/29	26.8	6.7	4.3	32.3	<2.0
03/30	28.3	6.5	6.3	24.8	
03/31	27.1	6.8	5.9	20.8	
平均值	26.5	6.6	5.5	24.8	2.5