

108 年 09 月南部科學園區台南園區污水處理廠放流水質

日期	Temp (°C)	pH	SS (mg/L)	COD (mg/L)	BOD ₅ (mg/L)
09/01	29.8	6.5	6.1	18.4	
09/02	28.7	6.8	3.0	18.0	
09/03	29.0	6.8	4.3	25.3	<2.0
09/04	28.5	6.8	4.6	22.3	<2.0
09/05	28.4	6.8	3.1	25.0	<2.0
09/06	28.7	7.0	4.9	24.8	<2.0
09/07	29.8	6.6	2.6	19.9	
09/08	29.8	6.6	3.0	19.5	
09/09	28.6	6.8	<2.5	27.5	
09/10	28.7	6.8	4.7	27.5	<2.0
09/11	28.4	6.7	3.7	22.6	<2.0
09/12	28.5	6.7	3.9	25.6	<2.0
09/13	29.0	6.9	5.0	23.9	
09/14	30.1	6.6	3.8	23.5	
09/15	29.8	6.7	4.1	23.1	
09/16	28.9	7.0	5.3	25.1	
09/17	28.8	6.8	4.2	23.5	<2.0
09/18	28.3	6.8	4.0	20.6	<2.0
09/19	28.9	7.0	5.5	24.6	<2.0
09/20	28.1	6.9	3.6	18.4	<2.0
09/21	29.5	6.7	4.3	28.1	
09/22	26.6	6.8	5.1	23.3	
09/23	28.0	6.8	4.3	21.3	
09/24	28.0	6.9	5.2	23.1	<2.0
09/25	28.2	6.8	4.9	25.1	<2.0
09/26	27.9	6.9	4.1	27.4	<2.0
09/27	28.1	6.8	5.8	22.9	<2.0
09/28	29.9	6.8	5.1	24.4	
09/29	29.9	6.6	3.5	26.8	
09/30	28.8	6.8	<2.5	28.8	
平均值	28.8	6.8	4.2	23.7	<2.0