

107 年 11 月南部科學園區台南園區污水處理廠放流水質

| 日期 | Temp (°C) | pH | SS (mg/L) | COD (mg/L) | BOD ₅ (mg/L) |
|-------|-----------|-----|-----------|------------|-------------------------|
| 11/01 | 27.2 | 6.8 | <2.5 | 25.0 | <2.0 |
| 11/02 | 27.0 | 6.7 | 4.4 | 24.7 | <2.0 |
| 11/03 | 27.7 | 6.8 | 6.3 | 24.0 | |
| 11/04 | 30.4 | 6.6 | 2.6 | 24.8 | |
| 11/05 | 28.0 | 6.6 | 6.0 | 24.0 | |
| 11/06 | 28.0 | 6.6 | 3.5 | 20.8 | <2.0 |
| 11/07 | 28.0 | 6.8 | 2.8 | 21.5 | <2.0 |
| 11/08 | 28.0 | 6.7 | <2.5 | 23.0 | <2.0 |
| 11/09 | 28.2 | 6.7 | 4.8 | 25.4 | <2.0 |
| 11/10 | 28.8 | 6.7 | 4.6 | 26.9 | |
| 11/11 | 29.0 | 6.7 | 4.3 | 24.9 | |
| 11/12 | 28.0 | 6.8 | 4.3 | 29.3 | |
| 11/13 | 27.9 | 6.8 | 5.7 | 22.8 | <2.0 |
| 11/14 | 27.7 | 6.8 | 6.6 | 29.5 | <2.0 |
| 11/15 | 27.7 | 6.9 | 5.9 | 25.3 | <2.0 |
| 11/16 | 27.8 | 6.8 | 5.8 | 30.0 | <2.0 |
| 11/17 | 29.0 | 6.6 | 6.9 | 26.1 | |
| 11/18 | 29.1 | 6.5 | 7.3 | 25.3 | |
| 11/19 | 27.8 | 6.6 | 4.4 | 26.1 | |
| 11/20 | 27.4 | 6.6 | 4.4 | 28.8 | <2.0 |
| 11/21 | 27.9 | 6.7 | 7.5 | 27.4 | <2.0 |
| 11/22 | 27.4 | 6.5 | 3.1 | 24.5 | <2.0 |
| 11/23 | 26.2 | 6.9 | 3.5 | 26.6 | <2.0 |
| 11/24 | 27.8 | 6.6 | 5.3 | 26.6 | |
| 11/25 | 27.8 | 6.7 | 6.0 | 27.0 | |
| 11/26 | 27.2 | 6.7 | 5.3 | 27.8 | <2.0 |
| 11/27 | 26.8 | 6.8 | 3.2 | 23.0 | <2.0 |
| 11/28 | 26.8 | 6.9 | 5.4 | 24.5 | |
| 11/29 | 26.7 | 6.8 | <2.5 | 25.9 | <2.0 |
| 11/30 | 26.9 | 6.8 | 2.9 | 25.7 | <2.0 |
| 平均值 | 27.8 | 6.7 | 4.7 | 25.6 | <2.0 |